

KẾT QUẢ ONLINE TRẠM QTTĐ KCN KHAI QUANG THÁNG 5/2025

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
1	00:00 01/05/2025	1.88	19.56	6.98	28.81	372.96	0.67	51.74
2	01:00 01/05/2025	1.89	19.57	7.03	28.79	33.34	0.68	31.14
3	02:00 01/05/2025	1.89	19.59	6.94	28.89	221.83	0.67	778.77
4	03:00 01/05/2025	1.90	19.58	6.92	29.01	326.72	0.71	414.75
5	04:00 01/05/2025	1.89	19.55	6.97	28.81	392.62	0.70	158.72
6	05:00 01/05/2025	1.89	19.55	7.02	28.80	475.61	0.69	40.70
7	06:00 01/05/2025	1.90	19.57	6.99	28.80	528.28	0.68	599.20
8	07:00 01/05/2025	1.90	19.54	6.94	28.67	673.38	0.67	585.84
9	08:00 01/05/2025	1.91	19.58	6.96	28.65	676.24	0.67	176.29
10	09:00 01/05/2025	1.90	19.57	6.89	28.77	419.99	0.68	1,103.88
11	10:00 01/05/2025	1.91	19.55	6.93	28.67	364.89	0.67	73.05
12	11:00 01/05/2025	1.91	19.55	6.95	28.64	522.93	0.66	374.91
13	12:00 01/05/2025	1.91	19.55	6.89	28.60	469.60	0.65	384.44
14	13:00 01/05/2025	1.91	19.56	6.95	28.66	455.40	0.66	28.41
15	14:00 01/05/2025	1.92	19.58	6.90	28.82	320.79	0.66	1,330.67
16	15:00 01/05/2025	1.91	19.59	6.90	29.25	320.35	0.70	464.11
17	16:00 01/05/2025	1.91	19.52	6.89	28.86	386.33	0.69	532.46
18	17:00 01/05/2025	1.91	19.51	6.88	28.79	410.60	0.66	216.10
19	18:00 01/05/2025	1.91	19.52	6.92	28.79	519.65	0.66	179.62
20	19:00 01/05/2025	1.91	19.52	6.89	28.76	453.20	0.65	525.99
21	20:00 01/05/2025	1.91	19.56	6.91	28.82	212.82	0.66	165.24
22	21:00 01/05/2025	1.91	19.58	6.88	28.97	0	0.69	1,059.37
23	22:00 01/05/2025	1.91	19.57	6.89	28.80	66.63	0.68	103.18
24	23:00 01/05/2025	1.91	19.54	6.93	28.75	66.82	0.68	296.52
25	00:00 02/05/2025	1.90	19.53	6.95	28.70	0	0.67	86.09
26	01:00 02/05/2025	1.91	19.53	6.98	28.69	0	0.67	30.77
27	02:00 02/05/2025	1.90	19.56	6.98	28.73	53.83	0.67	146.60
28	03:00 02/05/2025	1.91	19.58	6.86	29.03	359.32	0.70	460.73
29	04:00 02/05/2025	1.91	19.56	6.93	28.75	677.54	0.70	45.03
30	05:00 02/05/2025	1.92	19.56	6.97	28.68	678.99	0.68	28.46
31	06:00 02/05/2025	1.91	19.56	7.01	28.62	324.44	0.68	172.77
32	07:00 02/05/2025	1.92	19.53	6.92	28.49	328.96	0.64	569.91
33	08:00 02/05/2025	1.91	19.54	6.96	28.48	0	0.64	39.76
34	09:00 02/05/2025	1.92	19.54	6.95	28.52	0	0.64	654.10
35	10:00 02/05/2025	1.91	19.56	6.98	28.60	0	0.65	398.21
36	11:00 02/05/2025	1.92	19.56	7	28.64	0	0.66	140.03
37	12:00 02/05/2025	1.93	19.55	7.03	28.82	304.04	0.65	38.49
38	13:00 02/05/2025	1.92	19.56	7.08	29.06	330.36	0.67	14.68
39	14:00 02/05/2025	1.93	19.55	7.05	29	274.56	0.67	114.55
40	15:00 02/05/2025	1.92	19.57	7.09	29.10	650.54	0.69	16

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
41	16:00 02/05/2025	1.92	19.56	7.05	29.19	679.70	0.70	478.56
42	17:00 02/05/2025	1.91	19.55	6.96	29.23	487.44	0.70	213.68
43	18:00 02/05/2025	1.91	19.55	7	29.20	530.11	0.69	133.45
44	19:00 02/05/2025	1.91	19.55	6.94	29.33	756.71	0.69	550.10
45	20:00 02/05/2025	1.91	19.56	6.99	29.22	559.27	0.71	33.52
46	21:00 02/05/2025	1.91	19.55	6.94	29.22	273.22	0.70	651.81
47	22:00 02/05/2025	1.92	19.59	6.94	29.37	333.98	0.71	743.51
48	23:00 02/05/2025	1.92	19.57	6.95	29.25	427.98	0.73	428.78
49	00:00 03/05/2025	1.91	19.57	6.91	29.25	473.84	0.70	374.40
50	01:00 03/05/2025	1.91	19.57	6.97	29.24	460.26	0.71	34.54
51	02:00 03/05/2025	1.93	19.60	6.93	29.24	244.74	0.70	1,201.03
52	03:00 03/05/2025	1.92	19.58	6.96	29.54	642.35	0.75	401.24
53	04:00 03/05/2025	1.92	19.58	6.94	29.18	726.47	0.74	535.55
54	05:00 03/05/2025	1.92	19.58	6.93	29.11	675.81	0.71	199.84
55	06:00 03/05/2025	1.91	19.58	6.97	29.07	526.18	0.71	150.88
56	07:00 03/05/2025	1.90	19.58	6.90	28.93	721	0.69	611.99
57	08:00 03/05/2025	1.91	19.59	6.94	29.02	673.12	0.69	153.47
58	09:00 03/05/2025	1.91	19.60	6.91	29.20	424.58	0.72	1,036.48
59	10:00 03/05/2025	1.91	19.59	6.92	29.19	354.17	0.70	667
60	11:00 03/05/2025	1.91	19.60	6.93	29.11	439.10	0.71	414.56
61	12:00 03/05/2025	1.91	19.59	6.90	29.05	337.16	0.69	413.18
62	13:00 03/05/2025	1.91	19.59	6.95	29.16	455.97	0.69	24.48
63	14:00 03/05/2025	1.92	19.61	6.92	29.27	295.74	0.69	1,331.22
64	15:00 03/05/2025	1.93	19.61	6.91	29.66	371.88	0.76	505.58
65	16:00 03/05/2025	1.93	19.60	6.92	29.31	722.42	0.76	502.94
66	17:00 03/05/2025	1.93	19.59	6.91	29.29	648.31	0.72	237.48
67	18:00 03/05/2025	1.93	19.60	6.95	29.31	475.54	0.73	139.70
68	19:00 03/05/2025	1.93	19.59	6.92	29.26	613.34	0.72	561.35
69	20:00 03/05/2025	1.93	19.60	6.95	29.31	673.44	0.72	128.44
70	21:00 03/05/2025	1.93	19.60	6.93	29.44	495.89	0.74	871.64
71	22:00 03/05/2025	1.93	19.61	6.93	29.38	346.13	0.72	556.97
72	23:00 03/05/2025	1.93	19.60	6.94	29.30	838.84	0.73	355.54
73	00:00 04/05/2025	1.93	19.60	6.92	29.24	844	0.71	383.56
74	01:00 04/05/2025	1.92	19.60	6.97	29.26	659.30	0.71	34.70
75	02:00 04/05/2025	1.93	19.61	6.92	29.27	242.83	0.70	1,341.40
76	03:00 04/05/2025	1.92	19.61	6.93	29.38	639.01	0.73	444.42
77	04:00 04/05/2025	1.92	19.60	6.93	29.21	670.43	0.71	525.49
78	05:00 04/05/2025	1.93	19.59	6.92	29.15	470.68	0.69	202.73
79	06:00 04/05/2025	1.93	19.62	6.92	29.25	439.34	0.70	771.85
80	07:00 04/05/2025	1.93	19.60	6.88	29.11	715.63	0.69	680.59
81	08:00 04/05/2025	1.93	19.61	6.91	29.16	408.56	0.69	154.28
82	09:00 04/05/2025	1.93	19.61	6.89	29.26	321.92	0.71	1,033.57

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
83	10:00 04/05/2025	1.93	19.61	6.88	29.29	345.21	0.70	676.16
84	11:00 04/05/2025	1.93	19.61	6.89	29.27	519.71	0.70	455.07
85	12:00 04/05/2025	1.93	19.59	6.87	29.22	368.42	0.68	420.12
86	13:00 04/05/2025	1.93	19.59	6.92	29.37	453.04	0.69	21.36
87	14:00 04/05/2025	1.96	19.61	6.92	29.49	292.72	0.71	1,006.28
88	15:00 04/05/2025	1.98	19.61	6.98	29.73	617.42	0.78	187.37
89	16:00 04/05/2025	1.97	19.59	6.92	29.54	689.85	0.76	491.95
90	17:00 04/05/2025	1.97	19.59	6.88	29.54	404.06	0.74	240.98
91	18:00 04/05/2025	2.02	19.60	6.92	29.55	0	0.74	192.87
92	19:00 04/05/2025	2.01	19.58	6.89	29.52	390.92	0.73	526.95
93	20:00 04/05/2025	2.03	19.59	6.93	29.55	605.31	0.73	128.20
94	21:00 04/05/2025	2.04	19.62	6.97	29.77	472.76	0.78	290.74
95	22:00 04/05/2025	2.06	19.63	6.93	29.65	376.57	0.76	655.75
96	23:00 04/05/2025	2.09	19.62	6.94	29.54	493.82	0.76	411.63
97	00:00 05/05/2025	2.09	19.59	6.91	29.43	273.19	0.72	288.53
98	01:00 05/05/2025	2.07	19.60	6.96	29.42	325.53	0.72	34.49
99	02:00 05/05/2025	2.08	19.60	6.92	29.45	244.55	0.71	1,305.64
100	03:00 05/05/2025	2.09	19.61	6.95	29.51	615.22	0.74	374.11
101	04:00 05/05/2025	2.09	19.59	6.93	29.38	676.70	0.72	520.96
102	05:00 05/05/2025	2.08	19.59	6.90	29.31	477.18	0.71	209.26
103	06:00 05/05/2025	2.10	19.60	6.94	29.30	477.84	0.71	139.44
104	07:00 05/05/2025	2.10	19.59	6.87	29.28	570.43	0.70	627.73
105	08:00 05/05/2025	2.08	19.60	6.91	29.30	676.34	0.70	114.45
106	09:00 05/05/2025	1.93	19.61	6.85	29.38	529.38	0.72	793.76
107	10:00 05/05/2025	1.83	19.61	6.87	29.43	349.77	0.72	649.60
108	11:00 05/05/2025	1.77	19.60	6.88	29.47	766.31	0.71	421.73
109	12:00 05/05/2025	1.76	19.60	6.84	29.55	596.79	0.71	422.46
110	13:00 05/05/2025	1.76	19.60	6.91	29.73	532.91	0.74	20.52
111	14:00 05/05/2025	1.77	19.63	6.89	29.87	275.48	0.76	1,279.27
112	15:00 05/05/2025	1.77	19.63	6.94	30.05	511.29	0.79	177.58
113	16:00 05/05/2025	1.77	19.62	6.91	30.08	377.40	0.79	466.92
114	17:00 05/05/2025	1.77	19.61	6.88	30.08	446.46	0.78	237.13
115	18:00 05/05/2025	1.77	19.63	6.89	30.18	528.46	0.78	706.36
116	19:00 05/05/2025	1.76	19.62	6.87	30.15	697.84	0.82	674.58
117	20:00 05/05/2025	1.76	19.62	6.92	30.10	668	0.84	35.29
118	21:00 05/05/2025	1.77	19.62	6.92	29.92	466	0.81	661.93
119	22:00 05/05/2025	1.77	19.64	6.93	30.02	356.62	0.81	321.43
120	23:00 05/05/2025	1.77	19.63	6.95	29.97	817.48	0.81	340.81
121	00:00 06/05/2025	1.76	19.62	6.90	29.98	830.32	0.81	396.90
122	01:00 06/05/2025	1.76	19.62	6.98	29.92	519.45	0.81	38.06
123	02:00 06/05/2025	1.77	19.64	6.89	29.96	268.65	0.80	1,333.21
124	03:00 06/05/2025	1.76	19.65	6.92	30.09	617.13	0.85	613.83

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
125	04:00 06/05/2025	1.76	19.62	6.86	29.93	726.57	0.82	525.97
126	05:00 06/05/2025	1.76	19.63	6.86	29.86	651.09	0.80	216.26
127	06:00 06/05/2025	1.77	19.66	6.86	29.89	531.75	0.79	749.54
128	07:00 06/05/2025	1.77	19.64	6.83	29.81	645.47	0.79	702.41
129	08:00 06/05/2025	1.77	19.66	6.88	29.83	532.60	0.79	160.11
130	09:00 06/05/2025	1.77	19.66	6.87	29.99	329.38	0.82	1,090.47
131	10:00 06/05/2025	1.77	19.66	6.79	29.96	352.43	0.79	668.04
132	11:00 06/05/2025	1.77	19.66	6.80	29.93	413.28	0.79	464.25
133	12:00 06/05/2025	1.76	19.64	6.78	29.98	250.61	0.79	429.43
134	13:00 06/05/2025	1.76	19.64	6.85	30.09	330.74	0.81	24.81
135	14:00 06/05/2025	1.77	19.67	6.82	30.24	303.07	0.83	1,130.52
136	15:00 06/05/2025	1.77	19.70	6.88	30.54	621.87	0.93	465.34
137	16:00 06/05/2025	1.77	19.66	6.80	30.32	672.32	0.90	481.92
138	17:00 06/05/2025	1.77	19.65	6.78	30.34	635.03	0.86	248.78
139	18:00 06/05/2025	1.77	19.66	6.83	30.33	449.92	0.87	118.59
140	19:00 06/05/2025	1.76	19.65	6.77	30.33	695.30	0.87	578.38
141	20:00 06/05/2025	1.76	19.66	6.82	30.28	682.51	0.88	37.62
142	21:00 06/05/2025	1.76	19.66	6.79	30.30	509.19	0.87	646.34
143	22:00 06/05/2025	1.77	19.70	6.76	30.38	354.62	0.87	728.84
144	23:00 06/05/2025	1.77	19.68	6.79	30.29	811.12	0.89	405.84
145	00:00 07/05/2025	1.76	19.66	6.77	30.28	853.15	0.87	401.53
146	01:00 07/05/2025	1.76	19.67	6.83	30.25	629.82	0.87	35.34
147	02:00 07/05/2025	1.77	19.68	6.78	30.30	247.99	0.85	1,310.44
148	03:00 07/05/2025	1.77	19.69	6.78	30.36	621.90	0.89	475.23
149	04:00 07/05/2025	1.76	19.67	6.77	30.25	726.86	0.87	510.23
150	05:00 07/05/2025	1.76	19.66	6.77	30.18	709.81	0.84	220.93
151	06:00 07/05/2025	1.77	19.70	6.76	30.24	530.28	0.83	740.50
152	07:00 07/05/2025	1.77	19.67	6.73	30.15	561.66	0.84	718.51
153	08:00 07/05/2025	1.77	19.69	6.78	30.17	679.50	0.83	160.21
154	09:00 07/05/2025	1.77	19.69	6.78	30.34	560.08	0.88	1,076.12
155	10:00 07/05/2025	1.77	19.68	6.73	30.26	349.55	0.85	678.47
156	11:00 07/05/2025	1.77	19.68	6.74	30.23	820.08	0.85	467.29
157	12:00 07/05/2025	1.76	19.66	6.72	30.21	763.06	0.83	438.65
158	13:00 07/05/2025	1.76	19.67	6.79	30.29	563.65	0.85	27.52
159	14:00 07/05/2025	1.77	19.69	6.74	30.43	302.64	0.85	1,310.86
160	15:00 07/05/2025	1.77	19.72	6.79	30.68	618.94	0.93	487.70
161	16:00 07/05/2025	1.77	19.68	6.74	30.51	730.15	0.90	468.21
162	17:00 07/05/2025	1.77	19.68	6.72	30.53	681.73	0.87	252.05
163	18:00 07/05/2025	1.77	19.69	6.71	30.62	533.09	0.88	699.14
164	19:00 07/05/2025	1.77	19.69	6.71	30.56	700.74	0.92	706.22
165	20:00 07/05/2025	1.77	19.71	6.75	30.59	678.30	0.93	136.66
166	21:00 07/05/2025	1.77	19.71	6.75	30.68	504.51	1	909.43

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
167	22:00 07/05/2025	1.77	19.70	6.69	30.63	339.23	0.98	744.82
168	23:00 07/05/2025	1.77	19.69	6.71	30.57	753.68	1	446.83
169	00:00 08/05/2025	1.76	19.68	6.71	30.49	675.78	0.96	406.59
170	01:00 08/05/2025	1.76	19.69	6.76	30.49	483.91	0.95	35.70
171	02:00 08/05/2025	1.77	19.70	6.70	30.48	249.16	0.94	1,322.23
172	03:00 08/05/2025	1.77	19.73	6.72	30.61	621.75	1	619.81
173	04:00 08/05/2025	1.76	19.69	6.72	30.44	737.66	0.99	514.45
174	05:00 08/05/2025	1.76	19.69	6.71	30.38	710.81	0.93	230.65
175	06:00 08/05/2025	1.77	19.71	6.74	30.42	544.74	0.92	461.07
176	07:00 08/05/2025	1.77	19.70	6.70	30.32	654.89	0.91	647.27
177	08:00 08/05/2025	1.77	19.71	6.75	30.37	676.47	0.90	153.29
178	09:00 08/05/2025	1.77	19.72	6.72	30.52	502.20	0.94	1,035.61
179	10:00 08/05/2025	1.77	19.71	6.72	30.49	323.32	0.92	636.38
180	11:00 08/05/2025	1.77	19.71	6.73	30.49	477.48	0.95	387.98
181	12:00 08/05/2025	1.76	19.70	6.69	30.52	277.79	0.94	440.32
182	13:00 08/05/2025	1.76	19.70	6.76	30.67	563.82	0.98	21.49
183	14:00 08/05/2025	1.77	19.72	6.73	30.81	303.67	1	1,296.94
184	15:00 08/05/2025	1.77	19.76	6.78	31.13	621.96	1.14	559.24
185	16:00 08/05/2025	1.77	19.72	6.71	30.90	729.79	1.08	470.99
186	17:00 08/05/2025	1.77	19.72	6.71	30.92	631.06	1	252.10
187	18:00 08/05/2025	1.77	19.73	6.74	30.95	531.53	1	252.83
188	19:00 08/05/2025	1.76	19.72	6.72	30.99	700.19	1.04	596.80
189	20:00 08/05/2025	1.76	19.72	6.79	31.01	679.45	1.11	40.12
190	21:00 08/05/2025	1.76	19.73	6.73	30.93	507.57	1.10	639.49
191	22:00 08/05/2025	1.77	19.74	6.71	31.03	327.19	1.13	735.33
192	23:00 08/05/2025	1.77	19.74	6.73	30.96	843.73	1.20	424.09
193	00:00 09/05/2025	1.77	19.74	6.71	30.87	791.77	1.15	410.73
194	01:00 09/05/2025	1.77	19.74	6.77	30.85	565.46	1.14	36.04
195	02:00 09/05/2025	1.77	19.75	6.72	30.90	249.18	1.11	1,311.64
196	03:00 09/05/2025	1.77	19.76	6.72	31.03	622.47	1.19	572.07
197	04:00 09/05/2025	1.77	19.75	6.71	30.85	735.51	1.16	505.59
198	05:00 09/05/2025	1.77	19.74	6.72	30.80	702.28	1.09	235.77
199	06:00 09/05/2025	1.77	19.76	6.72	30.83	475.87	1.08	720.50
200	07:00 09/05/2025	1.77	19.75	6.69	30.75	672.53	1.06	710.50
201	08:00 09/05/2025	1.77	19.77	6.75	30.80	680.14	1.06	159.35
202	09:00 09/05/2025	1.77	19.77	6.75	31	388.23	1.15	1,086.30
203	10:00 09/05/2025	1.77	19.75	6.72	30.91	324.14	1.13	656.48
204	11:00 09/05/2025	1.77	19.76	6.71	30.87	559.47	1.16	442.77
205	12:00 09/05/2025	1.77	19.73	6.69	30.86	624.12	1.13	448.67
206	13:00 09/05/2025	1.77	19.74	6.76	30.99	697.25	1.17	23.70
207	14:00 09/05/2025	1.77	19.76	6.72	31.13	303.23	1.17	1,229.94
208	15:00 09/05/2025	1.77	19.79	6.76	31.50	613.97	1.35	468.26

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
209	16:00 09/05/2025	1.77	19.75	6.71	31.11	737.44	1.33	476.93
210	17:00 09/05/2025	1.77	19.74	6.70	31.08	697.15	1.26	279.76
211	18:00 09/05/2025	1.77	19.75	6.74	31.17	529.83	1.30	416.34
212	19:00 09/05/2025	1.77	19.73	6.72	31.05	700.36	1.32	603.16
213	20:00 09/05/2025	1.76	19.75	6.76	31.12	678.64	1.31	147.04
214	21:00 09/05/2025	1.77	19.77	6.73	31.26	534.77	1.41	1,033.47
215	22:00 09/05/2025	1.77	19.77	6.71	31.10	325.60	1.33	744.71
216	23:00 09/05/2025	1.77	19.75	6.73	31.05	820.43	1.32	424.87
217	00:00 10/05/2025	1.77	19.74	6.74	30.91	855.65	1.23	416.22
218	01:00 10/05/2025	1.77	19.75	6.78	30.91	697.01	1.23	32.90
219	02:00 10/05/2025	1.77	19.76	6.74	30.92	249.35	1.18	1,299.03
220	03:00 10/05/2025	1.77	19.78	6.73	31.09	623.45	1.25	641.82
221	04:00 10/05/2025	1.77	19.75	6.75	30.84	732.05	1.24	511.42
222	05:00 10/05/2025	1.77	19.74	6.76	30.78	685.32	1.15	239.74
223	06:00 10/05/2025	1.77	19.77	6.75	30.82	518.27	1.14	711.62
224	07:00 10/05/2025	1.77	19.76	6.75	30.72	673.32	1.13	723.95
225	08:00 10/05/2025	1.77	19.77	6.77	30.78	681.05	1.12	154.62
226	09:00 10/05/2025	1.77	19.78	6.76	30.95	358.62	1.18	1,046.05
227	10:00 10/05/2025	1.77	19.76	6.75	30.84	323.15	1.14	647.03
228	11:00 10/05/2025	1.77	19.76	6.76	30.80	526.28	1.14	440.64
229	12:00 10/05/2025	1.77	19.75	6.77	30.72	467.94	1.10	463.84
230	13:00 10/05/2025	1.77	19.75	6.82	30.74	659.31	1.11	31.72
231	14:00 10/05/2025	1.77	19.76	6.79	30.76	292.25	1.10	1,234.30
232	15:00 10/05/2025	1.77	19.81	6.78	31.05	613.80	1.22	496.21
233	16:00 10/05/2025	1.77	19.75	6.80	30.73	726.52	1.21	483.14
234	17:00 10/05/2025	1.77	19.75	6.81	30.66	679.26	1.11	293.09
235	18:00 10/05/2025	1.77	19.76	6.83	30.71	528.52	1.11	253.85
236	19:00 10/05/2025	1.77	19.76	6.82	30.62	619.56	1.09	615.46
237	20:00 10/05/2025	1.77	19.77	6.85	30.66	675	1.10	149.27
238	21:00 10/05/2025	1.77	19.79	6.79	30.79	526.49	1.17	1,008.78
239	22:00 10/05/2025	1.77	19.78	6.79	30.61	322.80	1.11	747.64
240	23:00 10/05/2025	1.77	19.77	6.82	30.51	817.61	1.10	431.72
241	00:00 11/05/2025	1.77	19.76	6.83	30.38	815.44	1.03	422.94
242	01:00 11/05/2025	1.77	19.76	6.88	30.29	487.36	1.02	35.99
243	02:00 11/05/2025	1.77	19.77	6.84	30.30	271.59	0.98	1,292.64
244	03:00 11/05/2025	1.77	19.80	6.81	30.48	326.69	1.03	538.99
245	04:00 11/05/2025	1.77	19.77	6.84	30.25	524.98	1.02	497.03
246	05:00 11/05/2025	1.77	19.76	6.86	30.13	681.93	0.95	242.53
247	06:00 11/05/2025	1.77	19.77	6.88	30.14	530.73	0.94	626.23
248	07:00 11/05/2025	1.77	19.77	6.85	30.05	630.47	0.93	674.41
249	08:00 11/05/2025	1.77	19.78	6.88	30.03	678.85	0.92	158.67
250	09:00 11/05/2025	1.77	19.80	6.83	30.17	561.61	0.95	1,026.30

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
251	10:00 11/05/2025	1.77	19.78	6.89	29.97	264.37	0.93	380.79
252	11:00 11/05/2025	1.77	19.78	6.91	29.94	603.87	0.91	304.52
253	12:00 11/05/2025	1.77	19.76	6.85	29.92	628.96	0.87	462.04
254	13:00 11/05/2025	1.77	19.77	6.91	29.92	656.69	0.89	27.17
255	14:00 11/05/2025	1.77	19.78	6.88	29.99	300.36	0.89	1,304.73
256	15:00 11/05/2025	1.77	19.82	6.86	30.36	618.54	0.95	537.42
257	16:00 11/05/2025	1.77	19.77	6.86	30.09	530.30	0.95	458.13
258	17:00 11/05/2025	1.77	19.77	6.85	30.03	245.90	0.90	283.96
259	18:00 11/05/2025	1.77	19.77	6.88	30.06	327.39	0.90	654.56
260	19:00 11/05/2025	1.77	19.76	6.87	30.02	301.01	0.91	718.66
261	20:00 11/05/2025	1.77	19.77	6.91	29.93	530.12	0.92	45.45
262	21:00 11/05/2025	1.77	19.77	6.88	29.88	532.80	0.90	612.21
263	22:00 11/05/2025	1.77	19.78	6.90	29.89	272.65	0.91	536.61
264	23:00 11/05/2025	1.77	19.77	6.91	29.76	751.81	0.90	314.21
265	00:00 12/05/2025	1.77	19.76	6.88	29.77	782.41	0.86	426.30
266	01:00 12/05/2025	1.77	19.76	6.93	29.66	413.23	0.85	33.83
267	02:00 12/05/2025	1.77	19.77	6.89	29.69	271.75	0.82	956.22
268	03:00 12/05/2025	1.77	19.77	6.91	29.56	325.29	0.77	74.33
269	04:00 12/05/2025	1.77	19.77	6.91	29.54	377.95	0.76	474.43
270	05:00 12/05/2025	1.77	19.77	6.87	29.50	368.90	0.78	241.09
271	06:00 12/05/2025	1.77	19.79	6.91	29.49	413.08	0.78	630.48
272	07:00 12/05/2025	1.77	19.78	6.84	29.43	620.28	0.77	689.33
273	08:00 12/05/2025	1.77	19.79	6.91	29.34	674.95	0.77	145.53
274	09:00 12/05/2025	1.77	19.80	6.88	29.56	499.48	0.78	886.37
275	10:00 12/05/2025	1.77	19.79	6.90	29.47	314.59	0.79	97.86
276	11:00 12/05/2025	1.77	19.79	6.92	29.50	474.91	0.79	278.68
277	12:00 12/05/2025	1.77	19.78	6.83	29.58	308.98	0.79	464
278	13:00 12/05/2025	1.77	19.78	6.90	29.69	459.53	0.81	21.76
279	14:00 12/05/2025	1.77	19.78	6.88	29.87	300.28	0.82	1,231.24
280	15:00 12/05/2025	1.77	19.81	6.94	30.12	617.73	0.91	259.66
281	16:00 12/05/2025	1.77	19.79	6.87	29.97	724.29	0.91	431.09
282	17:00 12/05/2025	1.77	19.78	6.83	29.91	672.19	0.89	263.09
283	18:00 12/05/2025	1.77	19.78	6.89	29.85	525.76	0.88	71.76
284	19:00 12/05/2025	1.77	19.76	6.82	29.90	723.25	0.86	600.28
285	20:00 12/05/2025	1.77	19.78	6.88	29.86	674.33	0.88	127.94
286	21:00 12/05/2025	1.77	19.79	6.84	29.97	504.30	0.91	837.08
287	22:00 12/05/2025	1.77	19.79	6.83	29.91	320.82	0.89	728.30
288	23:00 12/05/2025	1.77	19.79	6.85	29.78	524.91	0.90	414.42
289	00:00 13/05/2025	1.77	19.78	6.81	29.71	791.86	0.87	436.60
290	01:00 13/05/2025	1.77	19.78	6.87	29.67	689.73	0.88	37.96
291	02:00 13/05/2025	1.77	19.80	6.84	29.63	265.98	0.87	1,278.16
292	03:00 13/05/2025	1.77	19.81	6.86	29.65	614.60	0.89	608.25

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
293	04:00 13/05/2025	1.77	19.80	6.82	29.52	723	0.85	493.05
294	05:00 13/05/2025	1.77	19.79	6.82	29.45	702.60	0.83	253.92
295	06:00 13/05/2025	1.77	19.80	6.86	29.47	522.29	0.82	523.54
296	07:00 13/05/2025	1.77	19.81	6.79	29.32	686.37	0.81	683.06
297	08:00 13/05/2025	1.77	19.81	6.84	29.34	467.48	0.80	155.59
298	09:00 13/05/2025	1.77	19.83	6.80	29.49	321.34	0.81	1,038.06
299	10:00 13/05/2025	1.77	19.81	6.80	29.46	345.23	0.80	657.65
300	11:00 13/05/2025	1.77	19.81	6.81	29.46	420.47	0.81	453.35
301	12:00 13/05/2025	1.77	19.81	6.77	29.49	243	0.80	471.34
302	13:00 13/05/2025	1.77	19.81	6.84	29.66	478.80	0.82	22.46
303	14:00 13/05/2025	1.77	19.83	6.85	29.82	297.25	0.84	1,047.93
304	15:00 13/05/2025	1.78	19.86	6.91	30.19	614.21	0.95	453.98
305	16:00 13/05/2025	1.77	19.82	6.80	29.84	720.34	0.92	442
306	17:00 13/05/2025	1.77	19.81	6.78	29.84	684.95	0.88	273.25
307	18:00 13/05/2025	1.77	19.81	6.85	29.84	322.99	0.89	76.33
308	19:00 13/05/2025	1.77	19.82	6.78	29.84	588.26	0.88	616.53
309	20:00 13/05/2025	1.77	19.83	6.85	29.85	666.60	0.90	113.55
310	21:00 13/05/2025	1.77	19.84	6.82	30.01	554.24	0.93	777.53
311	22:00 13/05/2025	1.77	19.83	6.81	29.95	317.74	0.91	731.24
312	23:00 13/05/2025	1.77	19.83	6.83	29.86	761.92	0.93	427.32
313	00:00 14/05/2025	1.77	19.83	6.80	29.79	825.46	0.90	442.12
314	01:00 14/05/2025	1.77	19.83	6.86	29.78	569.16	0.92	37.06
315	02:00 14/05/2025	1.77	19.84	6.82	29.77	269.63	0.91	1,254.60
316	03:00 14/05/2025	1.77	19.84	6.84	29.74	319	0.93	355.71
317	04:00 14/05/2025	1.77	19.83	6.83	29.67	631.85	0.92	473.95
318	05:00 14/05/2025	1.77	19.83	6.81	29.62	701.23	0.90	258.45
319	06:00 14/05/2025	1.77	19.85	6.84	29.69	518.59	0.91	650.65
320	07:00 14/05/2025	1.77	19.84	6.79	29.56	720.81	0.90	728.04
321	08:00 14/05/2025	1.77	19.85	6.84	29.60	557.32	0.89	149.17
322	09:00 14/05/2025	1.77	19.86	6.80	29.72	0	0.91	981.18
323	10:00 14/05/2025	1.77	19.84	6.84	29.68	50.17	0.89	495.62
324	11:00 14/05/2025	1.77	19.85	6.86	29.67	199.98	0.91	55.74
325	12:00 14/05/2025	1.77	19.85	6.93	29.70	392.47	0.92	24.53
326	13:00 14/05/2025	1.77	19.83	6.89	29.60	462.65	0.89	338.44
327	14:00 14/05/2025	1.77	19.85	6.90	29.76	326.83	0.88	610.96
328	15:00 14/05/2025	1.78	19.87	6.88	29.85	330.76	0.94	833.07
329	16:00 14/05/2025	1.77	19.85	6.87	29.80	664.47	0.92	81.94
330	17:00 14/05/2025	1.77	19.85	6.93	29.82	761.98	0.94	82.69
331	18:00 14/05/2025	1.77	19.83	6.84	29.76	446.27	0.91	647.18
332	19:00 14/05/2025	1.77	19.84	6.89	29.74	753.94	0.91	41.56
333	20:00 14/05/2025	1.77	19.85	6.87	29.76	678.55	0.91	725.63
334	21:00 14/05/2025	1.77	19.89	6.85	30.03	531.49	0.97	524.01

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
335	22:00 14/05/2025	1.77	19.86	6.87	29.83	378.42	0.97	658.98
336	23:00 14/05/2025	1.77	19.84	6.85	29.77	733.86	0.92	485.80
337	00:00 15/05/2025	1.77	19.85	6.90	29.78	809.81	0.93	38.20
338	01:00 15/05/2025	1.77	19.84	6.85	29.71	660.50	0.91	674.09
339	02:00 15/05/2025	1.77	19.86	6.87	29.76	325.69	0.91	699.32
340	03:00 15/05/2025	1.77	19.87	6.84	29.77	620.21	0.94	1,006.08
341	04:00 15/05/2025	1.77	19.85	6.83	29.70	646.66	0.91	317.57
342	05:00 15/05/2025	1.77	19.85	6.88	29.68	762.87	0.92	94.67
343	06:00 15/05/2025	1.77	19.86	6.83	29.67	540.01	0.90	1,150.18
344	07:00 15/05/2025	1.77	19.86	6.84	29.61	752.20	0.92	192.64
345	08:00 15/05/2025	1.77	19.86	6.83	29.61	647.46	0.90	707.90
346	09:00 15/05/2025	1.77	19.89	6.83	29.78	329.77	0.94	519.50
347	10:00 15/05/2025	1.77	19.82	6.84	29.70	374.15	0.94	829.24
348	11:00 15/05/2025	1.77	19.66	6.83	29.71	471.41	0.93	581.57
349	12:00 15/05/2025	1.77	19.66	6.88	29.78	759.75	0.95	26.76
350	13:00 15/05/2025	1.77	19.67	6.81	29.85	637.75	0.94	690.43
351	14:00 15/05/2025	1.77	19.69	6.85	29.97	327.03	0.98	674.77
352	15:00 15/05/2025	1.77	19.69	6.87	30.19	617.58	1.07	888.33
353	16:00 15/05/2025	1.77	19.66	6.83	30.09	650.22	1.05	237.69
354	17:00 15/05/2025	1.77	19.67	6.91	30.12	695.14	1.08	81.50
355	18:00 15/05/2025	1.77	19.66	6.84	30.18	446.53	1.06	954.52
356	19:00 15/05/2025	1.77	19.66	6.86	30.14	634.66	1.10	54.80
357	20:00 15/05/2025	1.77	19.67	6.84	30.11	684.79	1.08	738.94
358	21:00 15/05/2025	1.77	19.71	6.85	30.27	505.49	1.14	525.27
359	22:00 15/05/2025	1.77	19.68	6.84	30.15	327.96	1.11	854.63
360	23:00 15/05/2025	1.77	19.67	6.82	30.11	737.73	1.08	606.83
361	00:00 16/05/2025	1.77	19.67	6.87	30.09	760.61	1.09	39.88
362	01:00 16/05/2025	1.77	19.67	6.85	30.06	565.39	1.06	681.28
363	02:00 16/05/2025	1.77	19.68	6.87	30.06	326.25	1.08	679.02
364	03:00 16/05/2025	1.77	19.69	6.85	30.03	618.71	1.09	850.87
365	04:00 16/05/2025	1.77	19.67	6.83	30	645.13	1.06	315.47
366	05:00 16/05/2025	1.77	19.68	6.89	29.97	758.96	1.08	95.57
367	06:00 16/05/2025	1.77	19.69	6.82	29.99	364.48	1.06	1,155.56
368	07:00 16/05/2025	1.77	19.68	6.84	29.92	748.56	1.08	205.40
369	08:00 16/05/2025	1.77	19.68	6.84	29.92	470.81	1.06	696.18
370	09:00 16/05/2025	1.77	19.70	6.86	29.99	271.53	1.09	345.72
371	10:00 16/05/2025	1.77	19.69	6.84	30	373.43	1.07	814.37
372	11:00 16/05/2025	1.77	19.68	6.81	29.99	608.28	1.05	595.93
373	12:00 16/05/2025	1.77	19.69	6.87	30	871.42	1.07	29.87
374	13:00 16/05/2025	1.77	19.69	6.80	30.06	608.45	1.05	696.48
375	14:00 16/05/2025	1.77	19.70	6.86	30.10	323.59	1.10	537.30
376	15:00 16/05/2025	1.77	19.70	6.88	30.19	580.25	1.16	807.25

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
377	16:00 16/05/2025	1.77	19.68	6.84	30.18	646.64	1.14	236.70
378	17:00 16/05/2025	1.77	19.69	6.89	30.20	710.05	1.17	75.16
379	18:00 16/05/2025	1.77	19.68	6.82	30.28	434.71	1.16	1,090.83
380	19:00 16/05/2025	1.77	19.68	6.83	30.24	564.72	1.19	124.98
381	20:00 16/05/2025	1.77	19.69	6.83	30.24	611.64	1.19	702.21
382	21:00 16/05/2025	1.77	19.72	6.86	30.33	465.66	1.27	542.71
383	22:00 16/05/2025	1.77	19.70	6.84	30.26	374.04	1.23	848.19
384	23:00 16/05/2025	1.77	19.69	6.82	30.23	674.10	1.20	627.64
385	00:00 17/05/2025	1.77	19.69	6.88	30.18	593.69	1.20	41.92
386	01:00 17/05/2025	1.77	19.70	6.84	30.17	433.66	1.17	677.23
387	02:00 17/05/2025	1.77	19.70	6.84	30.12	319.45	1.18	594.49
388	03:00 17/05/2025	1.77	19.70	6.83	30.10	496.94	1.18	672.90
389	04:00 17/05/2025	1.77	19.69	6.83	30.07	621.70	1.19	325.41
390	05:00 17/05/2025	1.77	19.69	6.89	29.99	690.49	1.20	91.51
391	06:00 17/05/2025	1.77	19.70	6.86	30.02	325.44	1.18	906.27
392	07:00 17/05/2025	1.77	19.70	6.92	29.91	556.29	1.18	53.81
393	08:00 17/05/2025	1.77	19.71	6.88	29.96	598.25	1.15	701.58
394	09:00 17/05/2025	1.77	19.73	6.86	30.09	467.91	1.22	571.46
395	10:00 17/05/2025	1.77	19.70	6.86	30.04	371.01	1.18	791.67
396	11:00 17/05/2025	1.77	19.70	6.84	30.10	724.49	1.15	550.52
397	12:00 17/05/2025	1.77	19.70	6.91	30.14	521.54	1.17	29.12
398	13:00 17/05/2025	1.77	19.71	6.84	30.27	380.17	1.19	683.45
399	14:00 17/05/2025	1.77	19.72	6.87	30.33	313.52	1.29	706
400	15:00 17/05/2025	1.77	19.71	6.93	30.49	543.95	1.40	1,009.14
401	16:00 17/05/2025	1.77	19.71	6.86	30.46	676.17	1.38	256.64
402	17:00 17/05/2025	1.77	19.70	6.93	30.36	724.34	1.42	79.44
403	18:00 17/05/2025	1.77	19.70	6.84	30.52	442.12	1.36	888.02
404	19:00 17/05/2025	1.77	19.69	6.90	30.48	684.44	1.45	54.65
405	20:00 17/05/2025	1.77	19.71	6.88	30.46	620.32	1.43	733.24
406	21:00 17/05/2025	1.77	19.74	6.88	30.54	495.54	1.56	535.40
407	22:00 17/05/2025	1.77	19.72	6.87	30.46	375.02	1.50	835.99
408	23:00 17/05/2025	1.77	19.70	6.84	30.47	674.60	1.45	646.97
409	00:00 18/05/2025	1.77	19.71	6.89	30.42	759.07	1.48	43.33
410	01:00 18/05/2025	1.77	19.71	6.85	30.39	420.86	1.43	675.60
411	02:00 18/05/2025	1.77	19.72	6.87	30.34	322.80	1.45	686.08
412	03:00 18/05/2025	1.77	19.72	6.87	30.30	323.24	1.47	1,028.87
413	04:00 18/05/2025	1.77	19.70	6.84	30.32	323.03	1.43	330.56
414	05:00 18/05/2025	1.77	19.70	6.89	30.27	729.08	1.47	85.87
415	06:00 18/05/2025	1.77	19.73	6.83	30.27	491.80	1.42	1,127.31
416	07:00 18/05/2025	1.77	19.72	6.84	30.19	685.55	1.44	184.36
417	08:00 18/05/2025	1.77	19.72	6.83	30.19	592.27	1.39	687.38
418	09:00 18/05/2025	1.77	19.73	6.87	30.27	365.14	1.46	406.65

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
419	10:00 18/05/2025	1.77	19.72	6.86	30.25	368.93	1.40	432.62
420	11:00 18/05/2025	1.77	19.71	6.83	30.32	493.20	1.35	442.48
421	12:00 18/05/2025	1.77	19.71	6.91	30.36	402.28	1.43	27.70
422	13:00 18/05/2025	1.77	19.71	6.82	30.48	239.04	1.43	673.15
423	14:00 18/05/2025	1.77	19.73	6.87	30.53	319.05	1.53	674.09
424	15:00 18/05/2025	1.77	19.73	6.89	30.66	548.33	1.68	919.16
425	16:00 18/05/2025	1.77	19.72	6.84	30.61	616.67	1.63	244.74
426	17:00 18/05/2025	1.77	19.72	6.90	30.63	520.96	1.65	63.93
427	18:00 18/05/2025	1.77	19.69	6.82	30.73	133.22	1.61	660.76
428	19:00 18/05/2025	1.77	19.69	6.87	30.64	287.60	1.73	38.94
429	20:00 18/05/2025	1.77	19.70	6.89	30.66	296.57	1.73	578.40
430	21:00 18/05/2025	1.77	19.73	6.93	30.73	414.31	1.90	285.07
431	22:00 18/05/2025	1.77	19.72	6.88	30.67	330.06	1.77	570.32
432	23:00 18/05/2025	1.77	19.72	6.88	30.57	502.91	1.75	198.02
433	00:00 19/05/2025	1.77	19.71	6.95	30.43	324.89	1.71	31.50
434	01:00 19/05/2025	1.77	19.70	6.88	30.49	268.91	1.51	692.34
435	02:00 19/05/2025	1.77	19.71	6.91	30.49	321.47	1.63	649.92
436	03:00 19/05/2025	1.77	19.71	6.91	30.45	319.61	1.62	728.13
437	04:00 19/05/2025	1.77	19.69	6.89	30.44	290.80	1.61	328.42
438	05:00 19/05/2025	1.77	19.69	6.95	30.35	0.35	1.64	80.07
439	06:00 19/05/2025	1.77	19.71	6.88	30.39	100.06	1.57	818.06
440	07:00 19/05/2025	1.77	19.71	6.94	30.29	133.32	1.60	49.72
441	08:00 19/05/2025	1.77	19.70	6.96	30.28	0	1.55	243.48
442	09:00 19/05/2025	1.77	19.69	7.01	30.26	0	1.56	42.94
443	10:00 19/05/2025	1.77	19.70	7.08	30.26	82.74	1.57	27.15
444	11:00 19/05/2025	1.77	19.70	7.13	30.28	328.67	1.56	20.93
445	12:00 19/05/2025	1.77	19.70	7.17	30.33	329.26	1.55	16.07
446	13:00 19/05/2025	1.77	19.70	7.05	30.39	370.82	1.47	251.49
447	14:00 19/05/2025	1.77	19.71	7.07	30.48	328.24	1.56	94.02
448	15:00 19/05/2025	1.77	19.73	7.04	30.62	560.58	1.68	628.70
449	16:00 19/05/2025	1.77	19.71	6.93	30.53	626.39	1.61	253.14
450	17:00 19/05/2025	1.77	19.72	7	30.50	749.68	1.69	66.19
451	18:00 19/05/2025	1.76	19.72	6.83	30.57	474.74	1.58	683.38
452	19:00 19/05/2025	1.76	19.73	6.92	30.46	693.23	1.66	45.22
453	20:00 19/05/2025	1.76	19.74	6.86	30.48	632.62	1.56	600.71
454	21:00 19/05/2025	1.76	19.73	6.86	30.41	498.98	1.58	129.22
455	22:00 19/05/2025	1.76	19.74	6.92	30.50	377.81	1.59	794.42
456	23:00 19/05/2025	1.76	19.74	6.81	30.50	670.79	1.60	666.90
457	00:00 20/05/2025	1.76	19.74	6.89	30.45	724.72	1.62	42.14
458	01:00 20/05/2025	1.77	19.76	6.81	30.40	472.38	1.55	672.22
459	02:00 20/05/2025	1.77	19.76	6.89	30.48	328.33	1.60	682.52
460	03:00 20/05/2025	1.77	19.76	6.86	30.45	326.74	1.70	1,029.61

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
461	04:00 20/05/2025	1.77	19.76	6.80	30.37	450.12	1.58	338.95
462	05:00 20/05/2025	1.77	19.75	6.87	30.37	555.57	1.62	78.58
463	06:00 20/05/2025	1.77	19.78	6.83	30.37	483.74	1.58	1,132.80
464	07:00 20/05/2025	1.77	19.77	6.84	30.31	690.30	1.63	209.80
465	08:00 20/05/2025	1.77	19.77	6.86	30.26	625.35	1.55	687.90
466	09:00 20/05/2025	1.77	19.77	6.96	30.38	468.98	1.65	396.12
467	10:00 20/05/2025	1.77	19.76	6.91	30.40	363.72	1.62	619.04
468	11:00 20/05/2025	1.77	19.77	6.83	30.41	253.59	1.59	471.23
469	12:00 20/05/2025	1.77	19.76	6.91	30.46	199.92	1.68	27.59
470	13:00 20/05/2025	1.77	19.76	6.89	30.49	256.78	1.70	376.49
471	14:00 20/05/2025	1.77	19.79	6.86	30.64	330.57	1.77	854.51
472	15:00 20/05/2025	1.77	19.78	6.97	30.78	562.60	2.05	405.25
473	16:00 20/05/2025	1.77	19.75	6.87	30.73	634.98	1.90	165.92
474	17:00 20/05/2025	1.77	19.76	6.96	30.80	679.05	1.94	13.05
475	18:00 20/05/2025	1.77	19.75	6.88	30.82	405.13	1.89	545.31
476	19:00 20/05/2025	1.77	19.76	6.82	30.78	637.51	1.97	188.68
477	20:00 20/05/2025	1.77	19.77	6.88	30.74	639.03	2.02	324.03
478	21:00 20/05/2025	1.77	19.79	6.89	30.85	530.58	2.13	887.94
479	22:00 20/05/2025	1.77	19.79	6.86	30.82	379.59	2.13	577.22
480	23:00 20/05/2025	1.76	19.76	6.80	30.82	673.36	2.10	899.76
481	00:00 21/05/2025	1.76	19.76	6.83	30.76	825.70	2.16	84.93
482	01:00 21/05/2025	1.76	19.76	6.84	30.74	552.56	2.13	413.73
483	02:00 21/05/2025	1.76	19.77	6.85	30.78	302.08	2.15	888.19
484	03:00 21/05/2025	1.76	19.77	6.93	30.70	330.40	2.25	561.89
485	04:00 21/05/2025	1.76	19.75	6.78	30.70	501.72	2	714.33
486	05:00 21/05/2025	1.76	19.75	6.85	30.66	757.51	2.08	51.76
487	06:00 21/05/2025	1.77	19.77	6.86	30.65	529.62	2.05	1,013.40
488	07:00 21/05/2025	1.76	19.76	6.83	30.60	503.90	2.02	262.96
489	08:00 21/05/2025	1.76	19.76	6.87	30.56	622.13	1.98	319.97
490	09:00 21/05/2025	1.77	19.78	6.84	30.64	466.28	1.94	916.45
491	10:00 21/05/2025	1.76	19.76	6.90	30.70	374.56	2.01	435.68
492	11:00 21/05/2025	1.76	19.75	6.79	30.71	724.21	1.97	691.62
493	12:00 21/05/2025	1.77	19.76	6.83	30.78	825.15	2.06	53.20
494	13:00 21/05/2025	1.77	19.76	6.83	30.88	658.26	2.16	385.18
495	14:00 21/05/2025	1.77	19.77	6.82	30.99	245.98	2.32	922.84
496	15:00 21/05/2025	1.77	19.79	6.96	31.07	329.56	2.65	529.04
497	16:00 21/05/2025	1.77	19.75	6.76	31.11	327.58	2.27	635.24
498	17:00 21/05/2025	1.77	19.76	6.83	31.08	693.17	2.36	24.52
499	18:00 21/05/2025	1.77	19.76	6.83	31.16	321.04	2.33	975.66
500	19:00 21/05/2025	1.76	19.75	6.80	31.19	482.86	2.53	381.90
501	20:00 21/05/2025	1.77	19.83	6.90	31.21	686.09	2.78	707.33
502	21:00 21/05/2025	1.76	19.76	6.78	31.16	675.55	2.55	501.87

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
503	22:00 21/05/2025	1.76	19.77	6.87	31.16	480.12	2.74	283.26
504	23:00 21/05/2025	1.77	19.77	6.78	31.14	423.51	2.64	702.82
505	00:00 22/05/2025	1.76	19.76	6.82	31.08	378.81	2.72	87.72
506	01:00 22/05/2025	1.76	19.76	6.81	31.04	346.36	2.55	409.34
507	02:00 22/05/2025	1.76	19.76	6.79	31.07	320.58	2.54	804.07
508	03:00 22/05/2025	1.76	19.76	6.82	30.99	801.06	2.61	316.08
509	04:00 22/05/2025	1.77	19.78	6.79	30.97	623.79	2.49	1,029.72
510	05:00 22/05/2025	1.76	19.77	6.79	30.95	757.75	2.50	55.87
511	06:00 22/05/2025	1.76	19.77	6.78	30.91	530	2.42	704.59
512	07:00 22/05/2025	1.76	19.76	6.80	30.85	604.05	2.40	174.09
513	08:00 22/05/2025	1.78	19.83	6.94	30.77	628.64	2.49	635.88
514	09:00 22/05/2025	1.76	19.76	6.74	30.85	468.30	2.12	549.85
515	10:00 22/05/2025	1.76	19.77	6.85	30.90	494.89	2.25	524.42
516	11:00 22/05/2025	1.76	19.76	6.76	30.93	582	2.23	864.35
517	12:00 22/05/2025	1.77	19.84	6.87	31.04	327.91	2.58	532.75
518	13:00 22/05/2025	1.77	19.77	6.77	31.02	327.12	2.48	402.61
519	14:00 22/05/2025	1.77	19.78	6.78	31.11	246.53	2.57	845.59
520	15:00 22/05/2025	1.76	19.78	6.82	31.09	429.69	2.71	250.99
521	16:00 22/05/2025	1.77	19.77	6.79	31.20	627.40	2.70	854.02
522	17:00 22/05/2025	1.77	19.78	6.83	31.18	654.71	2.84	31.43
523	18:00 22/05/2025	1.77	19.77	6.79	31.17	427.48	2.73	680.70
524	19:00 22/05/2025	1.77	19.76	6.78	31.18	476.54	2.71	209.41
525	20:00 22/05/2025	1.76	19.76	6.83	31.14	683.91	2.81	216.07
526	21:00 22/05/2025	1.76	19.77	6.74	31.09	687.29	2.64	503.52
527	22:00 22/05/2025	1.76	19.78	6.82	31.13	475.73	2.76	519.32
528	00:00 23/05/2025	1.76	19.78	6.83	31.04	789.40	2.76	53.87
529	01:00 23/05/2025	1.76	19.76	6.79	31.02	753.44	2.70	398.55
530	02:00 23/05/2025	1.76	19.77	6.78	31.04	420.71	2.59	794.30
531	03:00 23/05/2025	1.76	19.77	6.82	31.03	545.70	2.72	367.50
532	04:00 23/05/2025	1.77	19.82	6.83	30.93	630.83	2.73	1,326.66
533	09:00 23/05/2025	1.76	19.78	6.75	30.79	520.48	2.29	73.03
534	10:00 23/05/2025	1.76	19.78	6.77	30.83	375.65	2.32	529.40
535	11:00 23/05/2025	1.76	19.77	6.72	30.73	512.72	2.25	931.36
536	12:00 23/05/2025	1.77	19.81	6.88	30.75	666.76	2.47	432.64
537	13:00 23/05/2025	1.76	19.77	6.77	30.65	734.15	2.24	406.79
538	14:00 23/05/2025	1.77	19.78	6.74	30.63	418.53	2.10	876.02
539	15:00 23/05/2025	1.76	19.78	6.77	30.62	553.59	2.19	289.59
540	16:00 23/05/2025	1.76	19.76	6.72	30.55	679.90	2.07	900.22
541	17:00 23/05/2025	1.76	19.78	6.73	30.61	298.61	2.06	765.92
542	18:00 23/05/2025	1.77	19.80	6.92	30.63	166.77	2.36	501.29
543	19:00 23/05/2025	1.77	19.79	6.89	30.57	149.90	2.28	88.48
544	20:00 23/05/2025	1.77	19.80	6.82	30.57	277.30	2.17	619.45

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
545	21:00 23/05/2025	1.77	19.80	6.83	30.56	485.36	2.26	472.27
546	22:00 23/05/2025	1.77	19.79	6.84	30.52	528.45	2.26	303.50
547	23:00 23/05/2025	1.77	19.79	6.83	30.48	528.25	2.12	64.38
548	00:00 24/05/2025	1.77	19.82	6.87	30.47	491.42	2.13	430.53
549	01:00 24/05/2025	1.77	19.79	6.78	30.44	303.99	2	1,318.34
550	02:00 24/05/2025	1.76	19.77	6.73	30.37	562.77	1.89	293.60
551	03:00 24/05/2025	1.77	19.79	6.79	30.41	681.52	1.96	742.35
552	04:00 24/05/2025	1.77	19.79	6.79	30.38	742.70	1.99	554.23
553	05:00 24/05/2025	1.77	19.78	6.82	30.32	527.02	1.98	37.91
554	06:00 24/05/2025	1.77	19.78	6.76	30.28	520.42	1.82	1,345.32
555	07:00 24/05/2025	1.77	19.77	6.80	30.22	784.10	1.80	149.17
556	08:00 24/05/2025	1.77	19.78	6.78	30.24	862.13	1.76	555.15
557	09:00 24/05/2025	1.77	19.81	6.80	30.28	630.99	1.87	649.11
558	10:00 24/05/2025	1.77	19.81	6.77	30.23	98.03	1.88	384.94
559	11:00 24/05/2025	1.77	19.78	6.68	30.12	274.31	1.69	1,250.52
560	12:00 24/05/2025	1.77	19.83	6.77	30.19	864.35	1.78	470.59
561	13:00 24/05/2025	1.77	19.82	6.78	30.17	655.62	1.82	485.24
562	14:00 24/05/2025	1.77	19.80	6.82	30.07	828.33	1.79	36.23
563	15:00 24/05/2025	1.77	19.82	6.81	30.12	850.19	1.75	816.47
564	16:00 24/05/2025	1.77	19.79	6.70	30.07	540.39	1.65	865.84
565	17:00 24/05/2025	1.77	19.79	6.74	30.04	528.20	1.65	39.96
566	18:00 24/05/2025	1.77	19.79	6.78	29.98	696.01	1.67	29.21
567	19:00 24/05/2025	1.77	19.83	6.84	30.04	606.59	1.72	403.17
568	20:00 24/05/2025	1.77	19.81	6.78	29.97	666.84	1.73	456.81
569	21:00 24/05/2025	1.77	19.77	6.71	29.94	549.04	1.58	1,060.13
570	22:00 24/05/2025	1.76	19.77	6.74	29.85	763.84	1.59	69.21
571	23:00 24/05/2025	1.77	19.82	6.73	29.80	291.32	1.59	869.77
572	00:00 25/05/2025	1.77	19.81	6.74	29.75	488.93	1.59	74.46
573	01:00 25/05/2025	1.77	19.79	6.69	29.77	542.21	1.48	1,186.31
574	02:00 25/05/2025	1.77	19.78	6.70	29.70	690.07	1.48	285.66
575	03:00 25/05/2025	1.77	19.82	6.82	29.74	622.96	1.56	543.37
576	04:00 25/05/2025	1.77	19.82	6.72	29.59	639.17	1.48	662
577	05:00 25/05/2025	1.77	19.78	6.77	29.61	378.63	1.44	388.34
578	06:00 25/05/2025	1.77	19.80	6.71	29.55	666.58	1.39	651.48
579	07:00 25/05/2025	1.77	19.81	6.77	29.60	597.46	1.47	496.76
580	08:00 25/05/2025	1.77	19.81	6.76	29.56	609.83	1.49	498.10
581	09:00 25/05/2025	1.77	19.79	6.68	29.51	515.89	1.35	1,041.10
582	10:00 25/05/2025	1.77	19.80	6.71	29.45	479.03	1.36	56.62
583	11:00 25/05/2025	1.77	19.82	6.69	29.49	246.77	1.33	911.69
584	12:00 25/05/2025	1.77	19.80	6.69	29.51	322.76	1.34	57.52
585	13:00 25/05/2025	1.77	19.79	6.69	29.54	321.55	1.33	1,147.81
586	14:00 25/05/2025	1.77	19.81	6.69	29.47	541.77	1.36	216.53

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
587	15:00 25/05/2025	1.77	19.83	6.80	29.62	625	1.45	519.14
588	16:00 25/05/2025	1.77	19.82	6.66	29.60	434.70	1.36	707.63
589	17:00 25/05/2025	1.77	19.81	6.72	29.55	321.52	1.40	40.51
590	18:00 25/05/2025	1.77	19.83	6.68	29.50	604.75	1.36	632.43
591	19:00 25/05/2025	1.77	19.82	6.69	29.41	597.04	1.36	84.11
592	20:00 25/05/2025	1.77	19.82	6.71	29.38	494.16	1.32	330.73
593	21:00 25/05/2025	1.77	19.79	6.67	29.43	266.21	1.29	1,027.29
594	22:00 25/05/2025	1.77	19.81	6.68	29.32	598.43	1.30	66.64
595	23:00 25/05/2025	1.77	19.84	6.64	29.33	534.17	1.25	673.12
596	00:00 26/05/2025	1.77	19.83	6.68	29.24	592.76	1.26	50.43
597	01:00 26/05/2025	1.77	19.82	6.68	29.29	518.34	1.24	1,173.43
598	02:00 26/05/2025	1.77	19.83	6.66	29.21	565.06	1.24	288.57
599	03:00 26/05/2025	1.77	19.82	6.70	29.11	318.32	1.22	151.12
600	04:00 26/05/2025	1.77	19.84	6.64	29.11	469.88	1.17	571.63
601	05:00 26/05/2025	1.77	19.79	6.67	29.11	310.16	1.18	749.23
602	06:00 26/05/2025	1.77	19.83	6.65	29.03	66.57	1.16	669.04
603	07:00 26/05/2025	1.77	19.82	6.76	28.97	0	1.23	463.70
604	08:00 26/05/2025	1.77	19.81	6.73	28.94	150.10	1.18	349.47
605	09:00 26/05/2025	1.77	19.80	6.75	28.90	247.85	1.13	265.27
606	10:00 26/05/2025	1.77	19.80	6.83	28.88	612.10	1.14	30.11
607	11:00 26/05/2025	1.77	19.82	6.90	28.84	540.95	1.18	319.19
608	12:00 26/05/2025	1.77	19.81	6.90	28.80	500.56	1.16	43.69
609	13:00 26/05/2025	1.77	19.81	6.82	28.89	327.22	1.10	497.52
610	14:00 26/05/2025	1.77	19.80	6.72	28.92	547.61	1.09	209.51
611	15:00 26/05/2025	1.77	19.79	6.78	28.92	635.67	1.10	137.93
612	16:00 26/05/2025	1.77	19.79	6.69	29.08	575.86	1.06	596.27
613	17:00 26/05/2025	1.77	19.80	6.75	29.06	432.71	1.11	698.17
614	18:00 26/05/2025	1.77	19.80	6.69	29.05	578.89	1.10	662.53
615	19:00 26/05/2025	1.77	19.79	6.70	29.03	605.68	1.14	76.36
616	20:00 26/05/2025	1.77	19.80	6.72	29.02	656.33	1.14	324.51
617	21:00 26/05/2025	1.77	19.78	6.71	29.12	448.50	1.16	1,063.96
618	22:00 26/05/2025	1.77	19.79	6.71	29	645.85	1.18	71.11
619	23:00 26/05/2025	1.77	19.81	6.74	29.07	551.29	1.21	942.79
620	00:00 27/05/2025	1.77	19.79	6.75	29.06	621.57	1.23	88.57
621	01:00 27/05/2025	1.77	19.82	6.70	29.04	531.06	1.18	1,188.73
622	02:00 27/05/2025	1.77	19.81	6.68	29.01	647.98	1.18	292.85
623	03:00 27/05/2025	1.77	19.82	6.81	28.92	627.07	1.24	466.24
624	04:00 27/05/2025	1.77	19.81	6.67	28.97	600.69	1.14	593.83
625	05:00 27/05/2025	1.77	19.78	6.71	28.97	529.09	1.16	763.97
626	06:00 27/05/2025	1.77	19.81	6.67	28.94	672.82	1.14	671.27
627	07:00 27/05/2025	1.77	19.81	6.76	28.94	601.72	1.21	470.23
628	08:00 27/05/2025	1.77	19.81	6.72	28.92	429.20	1.18	439.89

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
629	09:00 27/05/2025	1.77	19.82	6.68	28.91	275.82	1.13	1,064.62
630	10:00 27/05/2025	1.77	19.81	6.69	28.89	329.02	1.13	59.20
631	11:00 27/05/2025	1.77	19.84	6.73	28.90	427.67	1.14	998.80
632	12:00 27/05/2025	1.77	19.84	6.74	28.90	507.02	1.15	138.65
633	13:00 27/05/2025	1.77	19.80	6.68	28.91	332.37	1.12	1,117.57
634	14:00 27/05/2025	1.77	19.81	6.66	28.91	530.99	1.13	241.02
635	15:00 27/05/2025	1.77	19.82	6.72	28.88	636.09	1.15	133.67
636	16:00 27/05/2025	1.77	19.83	6.64	28.91	401.02	1.10	616.60
637	17:00 27/05/2025	1.77	19.80	6.72	28.85	336.06	1.15	362.80
638	18:00 27/05/2025	1.77	19.82	6.66	28.88	592.02	1.11	648.31
639	19:00 27/05/2025	1.77	19.82	6.67	28.84	607.15	1.13	77.27
640	20:00 27/05/2025	1.77	19.83	6.69	28.81	661.17	1.12	320.28
641	21:00 27/05/2025	1.77	19.80	6.70	28.83	451.65	1.12	1,082.74
642	22:00 27/05/2025	1.77	19.82	6.70	28.75	760.82	1.11	77.17
643	23:00 27/05/2025	1.77	19.82	6.66	28.80	519.53	1.09	669.96
644	00:00 28/05/2025	1.77	19.81	6.70	28.74	607.76	1.11	50.92
645	01:00 28/05/2025	1.77	19.81	6.71	28.73	434.86	1.09	1,193.08
646	02:00 28/05/2025	1.77	19.81	6.69	28.70	367.33	1.08	305.41
647	03:00 28/05/2025	1.77	19.84	6.79	28.65	508.80	1.12	507.38
648	04:00 28/05/2025	1.77	19.81	6.68	28.71	505.63	1.08	635.15
649	05:00 28/05/2025	1.76	19.79	6.74	28.67	327.64	1.11	762.69
650	06:00 28/05/2025	1.77	19.82	6.68	28.67	630.27	1.06	674.51
651	07:00 28/05/2025	1.77	19.81	6.80	28.62	616.66	1.15	431.16
652	08:00 28/05/2025	1.77	19.81	6.74	28.63	800.68	1.09	365.91
653	09:00 28/05/2025	1.77	19.80	6.70	28.68	403.80	1.08	738.41
654	10:00 28/05/2025	1.77	19.80	6.72	28.68	638.68	1.09	36.84
655	11:00 28/05/2025	1.77	19.81	6.64	28.79	523.81	1.07	699.51
656	12:00 28/05/2025	1.77	19.80	6.69	28.76	775.34	1.11	54.58
657	13:00 28/05/2025	1.77	19.79	6.72	28.84	552.76	1.10	1,244.45
658	14:00 28/05/2025	1.77	19.79	6.68	28.93	691.73	1.10	264.37
659	15:00 28/05/2025	1.77	19.81	6.80	29.10	642.97	1.21	413.95
660	16:00 28/05/2025	1.77	19.81	6.64	29.20	665.26	1.15	604.70
661	17:00 28/05/2025	1.77	19.80	6.72	29.14	545.07	1.21	801.61
662	18:00 28/05/2025	1.77	19.80	6.64	29.19	702.35	1.15	643.70
663	19:00 28/05/2025	1.77	19.83	6.76	29.20	602.01	1.27	458.73
664	20:00 28/05/2025	1.77	19.83	6.72	29.19	662.54	1.24	480
665	21:00 28/05/2025	1.77	19.79	6.69	29.25	468.43	1.22	1,138.65
666	22:00 28/05/2025	1.77	19.81	6.67	29.23	477.59	1.22	117.47
667	23:00 28/05/2025	1.77	19.81	6.69	29.20	219.98	1.24	992.01
668	00:00 29/05/2025	1.77	19.80	6.73	29.19	670.20	1.25	170.61
669	01:00 29/05/2025	1.77	19.80	6.70	29.17	400.85	1.21	1,197.39
670	02:00 29/05/2025	1.77	19.80	6.68	29.15	529.27	1.18	311.42

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
671	03:00 29/05/2025	1.77	19.83	6.79	29.14	635.76	1.26	523.91
672	04:00 29/05/2025	1.77	19.80	6.68	29.12	553.47	1.19	699.20
673	05:00 29/05/2025	1.77	19.80	6.74	29.10	329.33	1.24	204.48
674	06:00 29/05/2025	1.77	19.80	6.68	29.08	691.97	1.19	640.93
675	07:00 29/05/2025	1.77	19.81	6.76	29.06	610.46	1.26	378.81
676	08:00 29/05/2025	1.77	19.80	6.73	29.05	776.94	1.24	348.88
677	09:00 29/05/2025	1.77	19.79	6.71	29.09	514.12	1.21	1,174.61
678	10:00 29/05/2025	1.77	19.79	6.69	29.06	775.67	1.20	94.67
679	11:00 29/05/2025	1.77	19.81	6.66	29.11	551.49	1.17	791.87
680	12:00 29/05/2025	1.77	19.81	6.71	29.13	767.72	1.21	60.83
681	13:00 29/05/2025	1.77	19.79	6.73	29.17	420.86	1.21	1,248.38
682	14:00 29/05/2025	1.77	19.79	6.70	29.18	644.58	1.19	283.50
683	15:00 29/05/2025	1.77	19.82	6.82	29.35	626.56	1.27	490.59
684	16:00 29/05/2025	1.77	19.81	6.68	29.28	686.21	1.20	736.66
685	17:00 29/05/2025	1.77	19.79	6.77	29.32	438.26	1.25	752.66
686	18:00 29/05/2025	1.77	19.78	6.69	29.24	647.27	1.23	684.81
687	19:00 29/05/2025	1.77	19.81	6.78	29.29	598.52	1.27	393.57
688	20:00 29/05/2025	1.77	19.80	6.75	29.25	766.79	1.29	351.24
689	21:00 29/05/2025	1.76	19.78	6.74	29.25	494.06	1.24	1,133.45
690	22:00 29/05/2025	1.77	19.79	6.72	29.17	607.23	1.24	109.60
691	23:00 29/05/2025	1.77	19.80	6.73	29.16	546.52	1.23	915.06
692	00:00 30/05/2025	1.77	19.79	6.74	29.15	767.89	1.24	70.06
693	01:00 30/05/2025	1.77	19.80	6.76	29.14	546.14	1.25	1,265.98
694	02:00 30/05/2025	1.77	19.79	6.77	29.05	689.09	1.22	333.50
695	03:00 30/05/2025	1.77	19.82	6.81	29.11	625.05	1.24	463.70
696	04:00 30/05/2025	1.77	19.79	6.71	29.02	714.76	1.19	620.56
697	05:00 30/05/2025	1.76	19.78	6.77	29.06	535.65	1.23	825.79
698	06:00 30/05/2025	1.77	19.80	6.72	28.95	721.32	1.18	714.46
699	07:00 30/05/2025	1.77	19.82	6.79	29.06	575.56	1.18	518.20
700	08:00 30/05/2025	1.77	19.80	6.77	29.02	737.73	1.18	485.12
701	09:00 30/05/2025	1.77	19.78	6.75	28.95	519.07	1.14	1,167.30
702	10:00 30/05/2025	1.77	19.78	6.74	28.91	380.33	1.13	90.03
703	11:00 30/05/2025	1.77	19.81	6.73	29.10	243.61	1.14	973.74
704	12:00 30/05/2025	1.77	19.81	6.75	29.18	479.97	1.21	173.35
705	13:00 30/05/2025	1.77	19.77	6.74	29.13	534.19	1.19	1,208.37
706	14:00 30/05/2025	1.77	19.77	6.73	29.13	435.83	1.16	269.89
707	15:00 30/05/2025	1.77	19.81	6.81	29.40	601.24	1.22	465.76
708	16:00 30/05/2025	1.77	19.78	6.72	29.21	685.68	1.21	674.31
709	17:00 30/05/2025	1.77	19.79	6.79	29.30	525.66	1.24	35.38
710	18:00 30/05/2025	1.77	19.78	6.76	29.21	775.47	1.22	632.08
711	19:00 30/05/2025	1.77	19.83	6.79	29.40	576.92	1.24	465.91
712	20:00 30/05/2025	1.77	19.82	6.77	29.34	768.95	1.32	463.28

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
713	21:00 30/05/2025	1.77	19.77	6.72	29.22	490.54	1.23	894.09
714	22:00 30/05/2025	1.77	19.77	6.75	29.19	777.11	1.23	47.80
715	23:00 30/05/2025	1.77	19.79	6.75	29.22	576.35	1.22	986.42
716	00:00 31/05/2025	1.77	19.79	6.77	29.26	768.70	1.27	188.07
717	01:00 31/05/2025	1.77	19.79	6.76	29.21	554.35	1.27	1,236.36
718	02:00 31/05/2025	1.77	19.78	6.74	29.11	544.09	1.25	338.07
719	03:00 31/05/2025	1.77	19.82	6.78	29.27	625.28	1.28	514.02
720	04:00 31/05/2025	1.77	19.79	6.73	29.10	650.96	1.30	713.21
721	05:00 31/05/2025	1.76	19.77	6.75	29.15	548.33	1.30	821.29
722	06:00 31/05/2025	1.77	19.79	6.73	29.04	722.71	1.27	716.18
723	07:00 31/05/2025	1.77	19.80	6.77	29.19	577.71	1.25	479.39
724	08:00 31/05/2025	1.77	19.79	6.76	29.14	766.67	1.31	393.81
725	09:00 31/05/2025	1.77	19.78	6.74	29.10	526.19	1.25	1,177.27
726	10:00 31/05/2025	1.77	19.78	6.75	29.07	482.52	1.24	96.45
727	11:00 31/05/2025	1.77	19.80	6.74	29.23	245.32	1.23	984.88
728	12:00 31/05/2025	1.77	19.79	6.75	29.33	492.56	1.28	114.25
729	13:00 31/05/2025	1.77	19.77	6.75	29.38	545.32	1.29	1,183.05
730	14:00 31/05/2025	1.77	19.77	6.74	29.46	624.36	1.28	269.60
731	15:00 31/05/2025	1.77	19.80	6.80	29.91	621.48	1.41	442.05
732	16:00 31/05/2025	1.77	19.78	6.72	29.68	684.79	1.44	697.11
733	17:00 31/05/2025	1.77	19.78	6.76	29.68	544.41	1.40	26.61
734	18:00 31/05/2025	1.77	19.77	6.74	29.70	755.52	1.39	625.09
735	19:00 31/05/2025	1.77	19.84	6.79	30	576.12	1.53	441.31
736	20:00 31/05/2025	1.77	19.82	6.78	29.89	758.50	1.71	394.86
737	21:00 31/05/2025	1.76	19.76	6.72	29.83	319.55	1.59	1,126.61
738	22:00 31/05/2025	1.77	19.77	6.74	29.78	514.07	1.60	108.21
739	23:00 31/05/2025	1.77	19.79	6.74	29.80	245.34	1.60	991.67